

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Notice of Monitoring Violation by the ECWSD

March 3, 2022

The City of Ranger (PWSID TX0670004) purchases and distributes treated water from the Eastland County Water Supply District (ECWSD) (PWSID TX0670019) to City of Ranger customers. The ECWSD has violated the monitoring and reporting requirements set forth by the Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative code (30 TAC), Section 290, Subchapter F. Public water systems are required to submit monthly operating reports with operational data of the treatment, disinfection and quality of the water provided to their customers. The ECWSD failed to adequately monitor and report chlorine dioxide and chlorite data for November 2021.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial and chemical contamination. We did not complete all of the monitoring and/or reporting for chlorine dioxide and chlorite concentrations in November 2021, and therefore TCEQ cannot be sure of the safety of your drinking water during that time.

We are taking the following actions to address this issue:

The ECWSD has implemented standard operating procedures to ensure that samples are collected and reported when required.

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). If you want more information about the nature and significance of this violation, you may contact **Gerald Gunstanson at 254-647-3522**.