



400 West Main St
(254) 647-3522 Phone

Ranger, TX 76470
(254) 647-1407 Fax

Joe Pilgrim - Mayor
Gerald Gunstanson – City Manager
Savannah Fortenberry – City Secretary
Robert Alvarez – Public Works Director
Tammy Archer- Municipal Judge
Darrell Fox – Fire Chief

Mandatory Public Notification Language Notice of Drinking Water Treatment Technique Violation(s)

City of Ranger TX0670004 has violated the treatment technique requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches, During September and October, 2020, sufficient levels of chlorine residual were not met in more than five percent (5%) of monthly samples.

The following actions are being taken to address the issue:

The chlorine was increased. We also flushed extra to bring chloring into the system. We are back in compliance since November 1, 2020

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses).

You can do this by posting this notice in a public place or distributing copies by hand or mail. If you have questions regarding this matter, you may contact Robert Alvarez at 254-647-3522.